

26 22 Low-Voltage Transformers

26 22 13 – Low-Voltage Distribution Transformers

26 22 13.10 Dry Type Transformer		Crew	Daily Output	Labor-Hours	Unit	Material	2007 Bare Costs		Total	Total Incl O&P
							Labor	Equipment		
2300	3 phase, 480 volt primary 120/208 volt secondary									
2310	Ventilated, 3 kVA	1 Elec	.92	8.700	Ea.	805	380		1,185	1,450
2700	6 kVA	↓	.74	10.870		1,100	475		1,575	1,925
2900	9 kVA		.64	12.420		1,250	545		1,795	2,175
3100	15 kVA	2 Elec	1.01	15.810		1,675	695		2,370	2,875
3300	30 kVA	↓	.83	19.320		1,975	850		2,825	3,425
3500	45 kVA		.74	21.740		2,350	955		3,305	4,025
3700	75 kVA	↓	.64	24.840		3,550	1,100		4,650	5,525
3900	112.5 kVA	R-3	.83	24.150		4,725	1,050	197	5,972	6,975
4100	150 kVA		.78	25.580		6,150	1,100	209	7,459	8,650
4300	225 kVA	↓	.60	33.440		8,350	1,450	273	10,073	11,700
4500	300 kVA		.51	39.530		10,600	1,700	325	12,625	14,500
4700	500 kVA		.41	48.310		17,500	2,100	395	19,995	22,800
4800	750 kVA		.32	62.110		30,600	2,700	505	33,805	38,300
4820	1000 kVA	↓	.29	67.930		35,100	2,950	555	38,605	43,600
4850	K-4 rated, 15 kVA	2 Elec	1.01	15.810		1,825	695		2,520	3,050
4855	30 kVA		.83	19.320		2,800	850		3,650	4,375
4860	45 kVA	↓	.74	21.740		3,250	955		4,205	5,000
4865	75 kVA		.64	24.840		4,450	1,100		5,550	6,500
4870	112.5 kVA	R-3	.83	24.150		7,375	1,050	197	8,622	9,900
4875	150 kVA		.78	25.580		9,900	1,100	209	11,209	12,800
4880	225 kVA	↓	.60	33.440		15,000	1,450	273	16,723	19,000
4885	300 kVA		.51	39.530		20,800	1,700	325	22,825	25,800
4890	500 kVA	↓	.41	48.310		28,800	2,100	395	31,295	35,300
4900	K-13 rated, 15 kVA	2 Elec	1.01	15.810		2,400	695		3,095	3,675
4905	30 kVA		.83	19.320		3,300	850		4,150	4,900
4910	45 kVA	↓	.74	21.740		3,875	955		4,830	5,700
4915	75 kVA		.64	24.840		5,500	1,100		6,600	7,675
4920	112.5 kVA	R-3	.83	24.150		11,300	1,050	197	12,547	14,300
4925	150 kVA		.78	25.580		13,800	1,100	209	15,109	17,100
4930	225 kVA	↓	.60	33.440		20,100	1,450	273	21,823	24,600
4935	300 kVA		.51	39.530		28,200	1,700	325	30,225	34,000
4940	500 kVA	↓	.41	48.310		43,100	2,100	395	45,595	51,000
5020	480 volt primary 120/208 volt secondary									
5030	Nonventilated, 15 kVA	2 Elec	1.01	15.810	Ea.	3,400	695		4,095	4,750
5040	30 kVA	↓	.74	21.740		3,800	955		4,755	5,600
5050	45 kVA		.64	24.840		5,175	1,100		6,275	7,325
5060	75 kVA	↓	.60	26.760		7,550	1,175		8,725	10,100
5070	112.5 kVA	R-3	.78	25.580		10,300	1,100	209	11,609	13,200
5081	150 kVA	↓	.78	25.580		12,400	1,100	209	13,709	15,600
5090	225 kVA		.55	36.230		15,200	1,575	296	17,071	19,400
5100	300 kVA	↓	.46	43.480		18,200	1,875	355	20,430	23,200
5200	Low operating temperature (80°C), 30 kVA	2 Elec	.83	19.320		3,100	850		3,950	4,675
5210	45 kVA	↓	.74	21.740		4,650	955		5,605	6,550
5220	75 kVA		.64	24.840		6,200	1,100		7,300	8,450
5230	112.5 kVA	R-3	.83	24.150		11,000	1,050	197	12,247	13,900
5240	150 kVA	↓	.78	25.580		13,900	1,100	209	15,209	17,100
5250	225 kVA		.60	33.440		19,200	1,450	273	20,923	23,600
5260	300 kVA	↓	.51	39.530		22,900	1,700	325	24,925	28,100
5270	500 kVA	↓	.41	48.310		34,500	2,100	395	36,995	41,600
5380	3 phase, 5 kV primary 277/480 volt secondary									
5400	High voltage, 112.5 kVA	R-3	.78	25.580	Ea.	13,400	1,100	209	14,709	16,600
5410	150 kVA	↓	.60	33.440		14,600	1,450	273	16,323	18,500